



creating effective height safety solutions

# Certificate of Inspection

## Installed System

Certificate No :

03-02-RW4339

Site Barcode :

CLIENT	Buxton Constructions Pty Ltd	Assisi Aged Care Facility – Stage 2
ADDRESS	Suite 3, 16 Salmon Street	230 Rosanna Road
Port Melbourne	POSTCODE	VIC 3207
PHONE	03 9644 7000	FAX 03 9644 7044
		Rosanna VIC

ASSET TYPE	BAR CODE	COMISSION DATE	NEXT SERVICE	RATING	*COMPLYING STANDARDS	MANUFACTURED & INSTALLED BY	COMMENTS
Single Anchorage Points	SMAP5	27.11.2013	27.11.2014	15kN	1891.4.2009	RIS/RIS	38 Anchor Points Installed, visually inspected <b>pass</b>
Ladder Brackets	LBPS	27.11.2013	27.11.2014	150kg	1891.4.2009	RIS/RIS	3 Ladder Brackets Installed, visually inspected <b>pass</b>
Anchor Cable Strops	Strop	27.11.2013	27.11.2014	15kN	1891.4.2009	RIS/RIS	3 Anchor Cable Strops Installed, visually inspected <b>pass</b>

Supply & Install: Single Anchorage Points, Ladder Brackets, Anchor Cable Strops and Signage

\*Design and location of the Height Safety System is in accordance with AS/NZS 1891-4 – 2009 and local Regulatory Authorities.

AUTHORISED BY: Stephen Byrne

DATE: 27.11.2013

SIGNATURE:

SYDNEY: Tel: (02) 8781 2100 Fax: (02) 8781 2111	BRISBANE: Tel: (07) 3216 6413 Fax: (07) 3216 7745	CANBERRA: Tel: (02) 6280 7200 Fax: (02) 6239 1066	MELBOURNE: Tel: (03) 9545 3177 Fax: (03) 9545 3455	ADELAIDE: Tel: (08) 8241 0090 Fax: (08) 8241 0122
-------------------------------------------------------	---------------------------------------------------------	---------------------------------------------------------	----------------------------------------------------------	---------------------------------------------------------