

GENERAL NOTES:

- THE SEPARATE IS INDICATIVE OF THE PROPOSED NURSE CALL SYSTEM. THE SEPARATE IS INDICATIVE OF THE PROPOSED NURSE CALL CABLEING AND COMPONENTS NECESSARY TO PROVIDE A FULLY OPERATIONAL SYSTEM. ALLOW IN THE TENDER ALL ADDITIONAL EQUIPMENT (CABLEING AND COMPONENTS NOT SHOWN ON THE SEPARATE) THAT MAY BE REQUIRED TO PROVIDE A FULLY OPERATIONAL SYSTEM APPROPRIATE IN ACCORDANCE WITH THE SPECIFICATION AND CLIENT REQUIREMENTS.
- REFER TO THE DRAWINGS FOR THE PROPOSED LOCATIONS AND QUANTITIES OF NURSE CALL SYSTEM DEVICES TO BE PROVIDED.
- SUBMIT A NURSE CALL SYSTEM SCHEMATIC WITH THE WORK SHOP DRAWINGS FOR REVIEW AND APPROVAL.
- NURSE CALL SYSTEM INTERFACE MODULES (NCIM) SHALL BE RACK MOUNTED IN 19" WALL MOUNTED RACKS INSTALLED IN THE LOCATIONS SHOWN ON THE DRAWINGS.
- NURSE CALL SYSTEM HEAD END SHALL BE RACK MOUNTED IN THE ANTELUARY COMMS RACK (E3) INSTALLED IN THE MAIN COMMS ROOM.
- THE NURSE CALL HEAD END SYSTEM SHALL BE PROVIDED WITH 25% SPARE CAPACITY FOR FUTURE EXPANSION PLUS ADDITIONAL SPARE CAPACITY FOR EXPANSION INTO THE EXISTING NURSES HOME AND CONVENT. MINIMUM OF 35 BEDROOMS TO BE ALLOWED FOR IN THE EXISTING NURSES HOME.
- ALLOW FOR THE PROVISION OF 10 FLOOR "WET" MATS AND 10 BED "WET" MATS FOR USE IN DEPENDENT BEDROOMS.
- ALLOW FOR THE PROVISION OF 5 NURSE CALL LED SCREENS INSTALLED IN THE STAFF STATIONS.
- REFER TO DRAWING E002 FOR NURSE CALL SYSTEM STAGING REQUIREMENTS.
- REFER TO SPECIFICATION FOR THE PROVISION OF BATTERY BACK UP TO BE PROVIDED AT THE NURSE CALL SYSTEM HEAD END.

ABBREVIATIONS

- BP1 BEDROOM PANEL No. 1  
BMS BED MAT SENSOR  
CMS CHAIR MAT SENSOR  
EC EMERGENCY CALL  
ECC EMERGENCY CALL CANCEL  
FIP FIRE INDICATOR PANEL  
FMS FLOOR MAT SENSOR  
N2/NP NURSE CALL SYSTEM NURSE CALL  
NC NURSE CALL  
NCC NURSE CALL CANCEL  
NCM NURSE CALL INTERFACE MODULE  
NCR NURSE CALL RACK "Y"  
NCS NURSE CALL SYSTEM CONTROLLER  
NCSM NURSE CALL SYSTEM MONITOR  
NCSM (NIGHT LIGHT TOWER TOWER)  
WR WANDERER ALERT RECEIVER

