

Test Assisi 02102013

Site Name : Assisi - Wednesday 02 October 2013 - 12:01:30 PM

=====FAMCO MasterMinder Multi-Line Carrier System=====						
Unit Computer Number	Volt at start	Charge rate Unit	Volt at Cutoff	Date of Last Test	Duration of Test	Test Out- come
S/0115	5.94	BOOST	4.92	02/10/13	120	PASS
N/0116	7.38	BOOST	6.20	02/10/13	120	PASS
N/0117	7.98	BOOST	6.20	02/10/13	120	PASS
S/0118	6.18	BOOST	5.04	02/10/13	120	PASS
N/0119	7.38	BOOST	6.24	02/10/13	120	PASS
S/0120	5.94	BOOST	4.92	02/10/13	120	PASS
N/0121	8.02	BOOST	6.20	02/10/13	120	PASS
N/0122	7.38	BOOST	6.28	02/10/13	120	PASS
S/0123	6.34	BOOST	5.00	02/10/13	120	PASS
N/0124	8.06	BOOST	6.28	02/10/13	120	PASS
S/0125	6.34	BOOST	5.04	02/10/13	120	PASS
N/0126	7.38	BOOST	6.16	02/10/13	120	PASS
S/0127	6.18	BOOST	5.00	02/10/13	120	PASS
N/0128	7.82	BOOST	6.28	02/10/13	120	PASS
S/0129	5.86	BOOST	4.88	02/10/13	120	PASS
N/0130	7.86	BOOST	6.20	02/10/13	120	PASS
S/0131	5.98	BOOST	4.92	02/10/13	120	PASS
N/0132	7.42	BOOST	6.36	02/10/13	120	PASS
?/0133	UNIT NOT	COMMISSIONED				
?/0134	UNIT NOT	COMMISSIONED				
?/0135	UNIT NOT	COMMISSIONED				
?/0136	UNIT NOT	COMMISSIONED				
?/0137	UNIT NOT	COMMISSIONED				
?/0138	UNIT NOT	COMMISSIONED				
?/0139	UNIT NOT	COMMISSIONED				
?/0140	UNIT NOT	COMMISSIONED				
?/0141	UNIT NOT	COMMISSIONED				
?/0142	UNIT NOT	COMMISSIONED				
?/0143	UNIT NOT	COMMISSIONED				
?/0144	UNIT NOT	COMMISSIONED				
?/0145	UNIT NOT	COMMISSIONED				
?/0146	UNIT NOT	COMMISSIONED				
?/0147	UNIT NOT	COMMISSIONED				
?/0148	UNIT NOT	COMMISSIONED				
?/0149	UNIT NOT	COMMISSIONED				
S/0150	6.34	BOOST	5.04	02/10/13	120	PASS
N/0151	8.18	BOOST	6.16	02/10/13	120	PASS
S/0152	5.94	BOOST	4.92	02/10/13	120	PASS
N/0153	7.90	BOOST	6.20	02/10/13	120	PASS
N/0154	7.38	BOOST	6.32	02/10/13	120	PASS
S/0155	5.98	BOOST	4.92	02/10/13	120	PASS
S/0156	5.98	BOOST	4.92	02/10/13	120	PASS
N/0157	7.38	BOOST	6.28	02/10/13	120	PASS
N/0158	8.22	BOOST	6.24	02/10/13	120	PASS
N/0159	8.42	BOOST	6.36	02/10/13	120	PASS
S/0160	5.82	BOOST	4.88	02/10/13	120	PASS
N/0161	7.38	BOOST	6.28	02/10/13	120	PASS
S/0162	6.38	BOOST	4.96	02/10/13	120	PASS
S/0163	6.42	BOOST	4.96	02/10/13	120	PASS
S/0164	6.38	BOOST	5.00	02/10/13	120	PASS
N/0165	8.10	BOOST	6.28	02/10/13	120	PASS
N/0166	7.34	BOOST	6.24	02/10/13	120	PASS
N/0167	7.38	BOOST	6.20	02/10/13	120	PASS
S/0168	6.42	BOOST	5.04	02/10/13	120	PASS
N/0169	7.38	BOOST	6.20	02/10/13	120	PASS
S/0170	5.94	BOOST	4.92	02/10/13	120	PASS

Operation Completed.