

Monthly Test of Residual Current Devices (RCD's)

Company Name:

Site/Project Name or Location:

Tested tripping time of RCD's (using RCD Tester)
(FAST TRIP FOR TYPE 1, 2 OR 3 MUST BE LESS THAN 40 MS)

[illegible]

Name of Licence Holder, Conducting Tests:

Wiring Licence No:

Signature:

~~Tests:~~

Date: 01/10/13

RCD PERIODIC INSPECTION LIST

Monthly Test of Residual Current Devices (RCD's)

Company Name: XSTAF ELECTRICAL

Site/Project Name or Location: ASSIST CENTRE DB-5

Tested tripping time of RCD's (using RCD Tester)
(FAST TRIP FOR TYPE 1, 2 OR 3 MUST BE LESS THAN 40 MS)

RCD Type and Location	Nominal Trip Current mA	Test Results to include both reverse phase relationship readings in <u>Milliseconds (mS)</u>								Action Taken for Unsatisfactory Results			
		X1/2 No Trip Time		X1 Trip Time		X5 Fast Trip Time							
		0°	180°	ms	ms	0°	180°	ms	ms		0°	180°	
TYPE-1 DB-5	30 mA												
				ms	ms	ms	ms	ms	ms	ms	ms	ms	
RCD-23	"	OL	OL	OL	18	28	18	8					
" 24	"	OL	OL	OL	18	28	18	8					
" 25	"	OL	OL	OL	18	28	18	8					
" 26	"	OL	OL	OL	18	28	18	9					
" 27	"	OL	OL	OL	18	28	18	8					
" 28	"	OL	OL	OL	18	28	18	8					
" 29	"	OL	OL	OL	18	28	18	8					
" 30	"	OL	OL	OL	21	30	20	11					
" 33	"	OL	OL	OL	18	28	18	8					
" 34	"	OL	OL	OL	19	30	20	9					
" 37	"	OL	OL	OL	19	30	18	8					
" 38	"	OL	OL	OL	20	30	18	9					
" 39	"	OL	OL	OL	30	30	18	8					
" 42	"	OL	OL	OL	17	24	14	9					
" 47	"	OL	OL	OL	18	28	18	8					
" 48	"	OL	OL	OL	19	30	18	9					
" 49	"	OL	OL	OL	30	30	18	9					
" 50	"	OL	OL	OL	20	30	14	9					
" 51	"	OL	OL	OL	40	30	18	9					
" 52	"	OL	OL	OL	17	24	14	10					
" 53	"	OL	OL	OL	20	31	18	9					
" 54	"	OL	OL	OL	20	31	18	9					

Name of Licence Holder Conducting Tests: Tom GROSE
 Wiring Licence No: 16259 Date: 1/10/13
 Signature: [Signature]

RCD PERIODIC INSPECTION LIST

Monthly Test of Residual Current Devices (RCD's)

Company Name: XSMITH ELECTRICAL 00-6
 Site/Project Name or Location: ASSISTANT CENTRE

Tested tripping time of RCD's (using RCD Tester)
 (FAST TRIP FOR TYPE 1, 2 OR 3 MUST BE LESS THAN 40 MS)

RCD Type and Location	Nominal Trip Current mA	Test Results to include both reverse phase relationship readings in <u>Milliseconds (mS)</u>								Action Taken for Unsatisfactory Results			
		X1/2 No Trip Time		X1 Trip Time		X5 Fast Trip Time							
		0°	180°	ms	ms	0°	180°	ms	ms		0°	180°	
TYOE-1 OB-6	30mA			ms	ms	ms	ms	ms	ms				
				OL	OL	18	28	18	18	ms	ms	8	
	16	"		OL	OL	18	28	18	18	ms	ms	8	
	17	"		OL	OL	18	28	18	18	ms	ms	8	
	18	"		OL	OL	20	28	18	18	ms	ms	9	
	19	"		OL	OL	18	28	18	18	ms	ms	9	
	20	"		OL	OL	18	28	18	18	ms	ms	8	
	21	"		OL	OL	18	28	18	18	ms	ms	8	
	22	"		OL	OL	20	28	18	18	ms	ms	8	
	23	"		OL	OL	18	28	18	18	ms	ms	9	
	24	"		N/A									
	25	"		OL	OL	18	28	18	18	ms	ms	8	
	26	"		OL	OL	18	28	18	18	ms	ms	8	
	27	"		OL	OL	18	28	18	18	ms	ms	8	
	28	"		OL	OL	18	28	18	18	ms	ms	8	
	29	"		OL	OL	18	28	18	18	ms	ms	8	
	30	"		OL	OL	18	28	18	18	ms	ms	8	
31	"		OL	OL	20	28	18	18	ms	ms	8		
32	"		OL	OL	20	28	18	18	ms	ms	8		
33	"		OL	OL	17	24	14	14	ms	ms	9		
34	"		OL	OL	19	30	18	18	ms	ms	8		
35	"		OL	OL	36	24	18	18	ms	ms	9		
36	"		OL	OL	21	24	14	14	ms	ms	9		
37	"		OL	OL	19	30	18	18	ms	ms	8		

Name of Licence Holder Conducting Tests: Tony Gibson
 Wiring Licence No: 16234 10/13
 Signature: [Signature]

