

**STANDARD FORM OF INSTALLER'S STATEMENT FOR
FIRE ALARM SYSTEM**

(NORMATIVE)

1. Name of premises: Assisi Aged Care
2. Situated at: 230 Rosanna Road, Rosanna 3084
3. I/We have installed in the above premises
An alteration to the system of...Ampac Firefinder
A system of:
4. The system is connected to the.....ADT.....monitoring service provider
5. The system incorporates the following ancillary equipment: GFA for Mechanical services and Nurse call.
6. The quiescent load of ancillary equipment is: As per spec
7. Primary power voltage and source: 240 volt AC
8. Secondary battery type and capacity: Sealed lead acid
9. System maintenance agreement details: 12 months as per warranty
10. Portion/s of premises not protected by this system: NIL
11. I/We hereby certify that:
 - a. The installation is complete and has been thoroughly tested
 - b. The system is installed in accordance with the current requirements of AS 1670.1*
 - c. The system is installed in accordance with the attached design specification*
Except in regard to the following details*: NIL

Location of fire indicator panel: Main Entry