Assisi Aged Care

MAINTENANCE SCHEDULE

FIRE DAMPERS	MONTHLY	QUARTERLY	TRIANNUALLY	HALF YEARLY	YEARLY	FIVE-YEARLY	NOT APPLICABLE
Inspect for obstruction					X		
Confirm position correct					X		
Check for corrosion						X	
Check that mounting is sound						X	
Check that integrity for fire wall is not impaired where applicable						X	
Check correct operation						X	
Restore to correct position						X	
Report any fault to be rectified							