

(Draft of) **INSTALLATION COMPLIANCE CERTIFICATE — MECHANICAL SERVICES**  
(Signed letter in this form to be provided on mechanical contractors letterhead prior to practical completion.)

To: SWEET AUSTRALIA P/L (Building Surveyor)

Address: 179 BOWKE ST  
MELBOURNE VIC 3000

Reference: ASSISI CENTRE ROSANNA (Project Name)  
4906 (Project Number)

From: JBK INDUSTRIES P/L (Contractor)

Address: 3189 NEPEAN HIGHWAY ASPENDALE  
VICTORIA 3195

We hereby certify that the completed mechanical installation fully complies with all the requirements and intent of the Specification and drawings prepared by Waterman AHW (Vic) Pty Ltd, as well as all relevant Australian Standards and Regulations which apply to the installation.

These Australian Standards and Regulations include, but are not limited to:

AS 1668 Part 1, AS 1668 Part 2, AS 1670, AS 1851, AS 3000, AS 3666, AS 4254, Building Code of Australia, Gas Code, Plumbing Board.

We certify that all ventilation, fire, smoke control and life-safe systems, including fire dampers, smoke dampers and all Essential Services, installed as part of this Contract have been fully inspected, tested and commissioned in conjunction with other service contracts and that the whole operates in accordance with the relevant codes and requirements.

We also attach a copy of the independent certification of Essential Services.

Contractor's Name: JBK INDUSTRIES P/L

Signature: [Signature] 30/9/13 Date: [Signature]

Witness: [Signature] 30/9/13 Date: [Signature]

## 2.20 Substitutions and Alternatives

Should the Contractor consider that any part of the work could be done quicker, better or more effectively by substitution of materials or methods other than those specified, the details of such substitutions or alternatives shall be included in the Tender, including a comprehensive report in support of the proposals.

Where the words 'or equal approved' are used in this Specification, the Contractor may request permission to use a substitute for what is specified, provided they certify in writing that the substitute is of equal, or better quality and effectiveness than that specified.

ASSISI STAGE 2