

**ROBERT M. GAVIN**  
Accredited Certifier

Victoria  
ABN 92 240 310 142  
48 Baker Parade  
Ashburton Vic 3147  
Phone/Fax: (03) 98854407  
Mobile: 0417 034157  
gavin48@ozonline.com.au

**AUTOMATIC FIRE SPRINKLER SYSTEM**

**Ref.:** 4962

**Our Job No.** BG3209

**Date:** 10 October 2013

**Premises Name:** Assisi Centre  
**Address:** 230 Rosanna Road  
Rosanna  
**Date of Inspection:** 10 October 2013  
**Type of Report:** Sprinkler Alterations  
**Installing Contractor:** Rapid Fire Protection

---

**SUMMARY**

This report deals with the alterations and extensions to the sprinkler layout carried out for Stage 2 on ground floor of the new aged care and early retirement unit only, at the above mentioned premises.

An inspection was carried out and I certify that the work contracted by Rapid Fire Protection was found to comply with the requirements of AS2118-4.

**Note:**

- Residential sprinklers installed.
- No protection to fire isolated area on basement level.



**R.M. GAVIN**  
(Building Practitioner Reg. No. DP-SD103)

*This report is for the final inspection of the listed fire services at the time and date stated. All systems were indicated to be operational at the stated time.*

*Additions and work on the systems specified, after the time and date stated, are not covered by this report.*