



Australian Commercial Doors Pty Ltd
8/97 Bayfield Road East, Bayswater, Vic 3153
ACN 096 630 296 ABN 15 868 251 275

PH: (03) 9720 5766
Fax: (03) 9720 5388
sales@acdoors.com.au
www.acdoors.com.au

FIRE DOOR CERTIFICATE

Certificate Number 1553

This is to certify that the fire doorsets identified on the attached schedule have been inspected and labelled as required by appropriate regulatory authorities in accordance with Australian Standard AS 1905.1.

Doors have been manufactured by Australian Commercial Doors Pty Ltd, as per tested prototype, and frames have been installed correctly in all respects and the fire door has been installed as per AS1905.1, 2005


Applicant: Pyropanel Developments Pty Ltd
Certifier: Australian Commercial Doors Pty Ltd
Manufacturer: Australian Commercial Doors Pty Ltd

Builder: Buxton Constructions.

Project: Assis Centre

Address: 230 Rosanna Rd, Rosanna

Door No.	Door Sizes	Fire Rating	Tag No.
	2040 x 814/814 x 45	2 Hr	B06595/B06596


Australian Commercial Doors Pty Ltd


Date

Doorsets covered by this certificate are to be maintained in accordance with AS 1851 and the manufacturer's instructions. This certificate will only be issued on original letterhead and no part of this information can be reproduced without prior written consent of this company.