

3 June 2014

Mr. Joe Zita
Approval Systems
5 / 233 Cardigan Street
Carlton Vic 3053

Dear Joe,

RE: Assisi Age Care Centre Development - 230 Rosanna Road (Stage 3)
Fire & Acoustic Compliance

Buxton Construction confirms the wall framing / construction and plasterboard wall lining systems achieve the required fire rating and acoustic requirements.

The following internal wall systems were used:

- 90mm MPG10 Pine timber wall framing with plasterboard lining. Fyrecheck plaster was used on walls nominate to be 2 hour fire rated.
- 140mm concrete block wall with metal battens with plasterboard lining

CSR Plasterboard and insulation was used and installed as per wall types nominated on the Architectural drawings.

Yours faithfully,
Buxton Constructions (Vic) Pty Ltd

A handwritten signature in blue ink, appearing to read 'Daryl Marson', with a long horizontal stroke extending to the right.

Daryl Marson
Project Manager