

Date: 30th June 2014

Finadri Windows Pty Ltd
287 – 289 Victoria St
Brunswick

Re: Gilgen SLM Auto Door operator – Assisi Aged Care – 230 Rosanna Rd, Rosanna

To whom it may concern.

We hereby certify that the Gilgen SLM automatic door operators, as installed at the above listed site, comply with all relevant Australian Standards (AS5007-2007 and BCA 2.19) and may be accessed from exterior for entry via spring return key switch or swipe card and exited from inside via use of green domed push button in the event of power failure; so long as the backup battery is in full operating condition. Upon failure/draining of the backup battery the door lock will fail safe. The automatic door system is ready for use under occupancy conditions.

As the installation of the system is handed over to the customer, it is totally their responsibility to see that no operational changes are made to the installation, which may breach any of the above mentioned Standard requirements.

Yours sincerely
Doorways Pty Ltd



Joff Byron
Operations Manager