

COMMISSIONING SCHEDULE FOR COMTEL SYSTEM INSTALATIONS

STAGE: 3GND Floor
 DESCRIPTION: Access Control and CCTV
 PLAN REFERENCE NUMBER: E106
 PROJECT NAME: ASSISI CENTRE

Date Tested
12/06/2014



SYSTEM TYPE	SYMBOL ON PLANS	ROOM / DOOR	CABLE TYPE TO RUN	CABLE RUN DESTINATION	Fit off and comissioned	Notes
SECURITY D27	Keypad	Entry G139 Keypad	8 core Screened	CR3	Yes	
SECURITY D27	Keypad	Entry G139 Keypad	8 core Screened	Looped to keypad D27	Yes	
SECURITY D27	PW	Entry G139 B/Glass	4 core security Grey	CR3	Yes	
SECURITY D27	Breakglass	Entry G139 B/Glass	6 core security Grey	CR3	Yes	
SECURITY D27	Lock	Entry G139	6 core security 14/020	D27 Breakglass	Yes	
SECURITY D27	Reed 1	Entry G139 Reed Switch	4 core security White 7/020	CR3	Yes	
SECURITY D27	Reed 2	Entry G139 Reed Switch	4 core security White 7/020	D27 Reed 1	Yes	
SECURITY D27	Breakglass	Entry G139 B/Glass	fig 8 26/030	CR3	Yes	
SECURITY D28	Keypad	Ex Dining G171 Keypad	8 core Screened	CR3	Yes	
SECURITY D28	Keypad	Ex Dining G171 Keypad	8 core Screened	Looped to keypad D28	Yes	
SECURITY D28	PW	Ex Dining G171 B/Glass	4 core security Grey	CR3	Yes	
SECURITY D28	Breakglass	Ex Dining G171 B/Glass	6 core security Grey	CR3	Yes	
SECURITY D28	Lock	Ex Dining G171 Elect Lock	6 core security 14/020	D28 Breakglass	Yes	
SECURITY D28	Reed 1	Ex Dining G171 Reed Switch	4 core security White 7/020	CR3	Yes	
SECURITY D28	Reed 2	Ex Dining G171 Reed Switch	4core security White 7/020	CR3	Yes	
SECURITY D28	Breakglass	Ex Dining G171 B/Glass	fig 8 26/030	CR3	Yes	
SECURITY D29	Keypad	Corridor G153 Keypad	8 core Screened	CR3	Yes	
SECURITY D29	Keypad	Corridor G153 Keypad	8 core Screened	Looped to keypad D29	Yes	
SECURITY D29	PW	Corridor G153 B/Glass	4 core security Grey	CR3	Yes	
SECURITY D29	Breakglass	Corridor G153 B/Glass	6 core security Grey	CR3	Yes	
SECURITY D29	Lock	Corridor G153 Elect Lock	6 core security 14/020	D3 Breakglass	Yes	
SECURITY D29	Reed	Corridor G153 Reed Switch	4 core security White 7/020	CR3	Yes	
SECURITY D29	Breakglass	Corridor G153 B/Glass	fig 8 26/030	CR3	Yes	

COMMISSIONING SCHEDULE FOR COMTEL SYSTEM INSTALATIONS

STAGE: 3 GND Floor
 DESCRIPTION: Access Control and CCTV
 PLAN REFERENCE NUMBER: E106
 PROJECT NAME: ASSISI CENTRE

Date Tested
 12/06/2014



SYSTEM TYPE	SYMBOL ON PLANS	ROOM / DOOR	CABLE TYPE TO RUN	CABLE RUN DESTINATION	Fit off and comissioned	Notes
SECURITY D30	Keypad	Entry G144 Keypad	8 core Screened	CR3	Yes	
SECURITY D30	Keypad	Entry G144 Keypad	8 core Screened	Looped to keypad D30	Yes	
SECURITY D30	PW	Entry G144 B/Glass	4 core security Grey	CR3	Yes	
SECURITY D30	Breakglass	Entry G144 B/Glass	6 core security Grey	CR3	Yes	
SECURITY D30	Lock	Entry G144Doub Mag Lock	6 core security 14/020	D30 Breakglass	Yes	
SECURITY D30	Reed 1	Entry G144 Reed Switch	4 core security White 7/020	CR3	Yes	
SECURITY D30	Reed 2	Entry G144 Reed Switch	4 core security White 7/020	D30 Reed 1	Yes	
SECURITY D30	Breakglass	Entry G144 B/Glass	fig 8 26/030	CR3	Yes	
SECURITY D31	Keypad	Main Comm Entry Keypad	8 core Screened	CR3	Yes	
SECURITY D31	Keypad	Main Comm Entry Keypad	8 core Screened	Looped to keypad D31	Yes	
SECURITY D31	PW	Main Comm Entry B/Glass	4 core security Grey	CR3	Yes	
SECURITY D31	Breakglass	Main Comm Entry B/Glass	6 core security Grey	CR3	Yes	
SECURITY D31	Lock	Main Comm Entry Elect Lock	6 core security 14/020	D8 Breakglass	Yes	
SECURITY D31	Reed	Main Comm Entry Reed Switch	4core security White 7/020	CR3	Yes	
SECURITY D31	Breakglass	Main Comm Entry B/Glass	fig 8 26/030	CR3	Yes	
SECURITY D32	Keypad	SE Balcony Entry Keypad	8 core Screened	CR5	Yes	
SECURITY D32	Keypad	SE Balcony Entry Keypad	8 core Screened	Looped to keypad D32	Yes	
SECURITY D32	PW	SE Balcony Entry B/Glass	4 core security Grey	CR5	Yes	
SECURITY D32	Breakglass	SE Balcony Entry B/Glass	6 core security Grey	CR5	Yes	
SECURITY D32	Lock	SE Balcony EntryDoub Mag Lock	6 core security 14/020	D32 Breakglass	Yes	
SECURITY D32	Reed 1	SE Balcony Entry Reed Switch	4 core security White 7/020	CR5	Yes	
SECURITY D32	Breakglass	SE Balcony Entry B/Glass	fig 8 26/030	CR5	Yes	

COMMISSIONING SCHEDULE FOR COMTEL SYSTEM INSTALATIONS

STAGE: 3 GND Floor
 DESCRIPTION: Access Control and CCTV
 PLAN REFERENCE NUMBER: E106
 PROJECT NAME: ASSISI CENTRE

Date Tested
 12/06/2014

SYSTEM TYPE	SYMBOL ON PLANS	ROOM / DOOR	CABLE TYPE TO RUN	CABLE RUN DESTINATION	Fit off and comissioned	Notes
SECURITY D33	Keypad	SE Balcony Exit Keypad	8 core Screened	CR5	Yes	
SECURITY D33	Keypad	SE Balcony Exit Keypad	8 core Screened	Looped to keypad D33	Yes	
SECURITY D33	PW	SE Balcony Exit B/Glass	4 core security Grey	CR5	Yes	
SECURITY D33	Breakglass	SE Balcony Exit B/Glass	6 core security Grey	CR5	Yes	
SECURITY D33	Lock	SE Balcony ExitDoub Mag Lock	6 core security 14/020	D33 Breakglass	Yes	
SECURITY D33	Reed 1	SE Balcony Exit Reed Switch	4 core security White 7/020	CR5	Yes	
SECURITY D33	Breakglass	SE Balcony Exit B/Glass	fig 8 26/030	CR5	Yes	
SECURITY D34	Keypad	Corridor G154 Keypad	8 core Screened	CR5	Yes	
SECURITY D34	Keypad	Corridor G154 Keypad	8 core Screened	Looped to keypad D34	Yes	
SECURITY D34	PW	Corridor G154 B/Glass	4 core security Grey	CR5	Yes	
SECURITY D34	Breakglass	Corridor G154 B/Glass	6 core security Grey	CR5	Yes	
SECURITY D34	Lock	Corridor G154 Elect Lock	6 core security 14/020	D34 Breakglass	Yes	
SECURITY D34	Reed	Corridor G154 Reed Switch	4 core security White 7/020	CR5	Yes	
SECURITY D34	Breakglass	Corridor G154 B/Glass	fig 8 26/030	CR5	Yes	
CCTV 8	CCTV	Camera 8 Entry G139	Fig 8 26/030	CR3 main comms room	Yes	
CCTV 8	CCTV	Camera 8 Entry G139	Cat 5e Green	CR3 main comms room	Yes	Cameras focused
CCTV 9	CCTV	Camera 9 Enrty G144	Fig 8 26/030	CR3 main comms room	Yes	
CCTV 9	CCTV	Camera 9 Entry G144	Cat 5e Green	CR3 main comms room	Yes	Cameras focused
CCTV 10	CCTV	Camera 10 near comm CR3	Fig 8 26/030	CR3 main comms room	Yes	
CCTV 10	CCTV	Camera 10 near comm CR3	Cat 5e Green	CR3 main comms room	Yes	Cameras focused
CCTV 11	CCTV	Camera 11 Corridor G154	Fig 8 26/030	CR3 main comms room	Yes	
CCTV 11	CCTV	Camera 11 Corridor G154	Cat 5e Green	CR3 main comms room	Yes	Cameras focused
CCTV 12	CCTV	Camera 12 SE Balcony	Fig 8 26/030	CR3 main comms room	Yes	
CCTV 12	CCTV	Camera 12 SE Balcony	Cat 5e Green	CR3 main comms room	Yes	Cameras focused

