



Rev	Description	Checked	Date
A	TENDER ISSUE	JVG	30.6.11
B	REVISED TENDER ISSUE	JVG	30.6.11
C	REVISED TENDER ISSUE	JVG	30.6.11
D	CONSTRUCTION ISSUE	SL	21.11.11
E	REVISED CONSTRUCTION ISSUE	SL	21.11.11
F	REVISED CONSTRUCTION ISSUE	SL	21.11.11
G	REVISED CONSTRUCTION ISSUE	SL	21.11.11
H	REVISIONS AS CLOUSED	JVG	01.03.14

16.12.13 X06-AGED

Thomson
Adsett

Level 1
50/51 Sturt Street
South Melbourne
VIC 3205
www.thomsonadsett.com

Wateman
Associate Architect
60 Park Street, South Melbourne, Victoria 3205 Australia
t: (03) 9665 9900 f: (03) 9665 9999 wateman@wateman.com.au

ASSISI CENTRE
EXISTING AGED CARE BUILDING & NEW RETIREMENT ACCOMMODATION
230 ROSANNA RD, ROSANNA

ELECTRICAL SERVICES
GROUND FLOOR - SHEET 3
LIGHTING AND PUBLIC ADDRESS LAYOUT

Drawing No **E103** Revision **H**
Drawn **RG** Date **AUG 2010**
Checked **JV** Scale **1:50 @ B1**
Job No **4905**

CONSTRUCTION ISSUE

THESE DRAWINGS HAVE BEEN MARKED "CONSTRUCTION ISSUE" ON THE UNDERSI LANDING THAT THEY ARE TO BE USED AS THE BASIS FOR THE COMMENCEMENT OF THE SUB CONTRACTOR'S SHOP DRAWING PROCESS.

- ### GENERAL NOTES
- REFER TO DRAWING E101 AND E101 FOR LEGEND OF SYMBOLS, APPLICABLE NOTES AND LIGHTING CONTROLS.
 - REFER TO THE SPECIFICATION FOR DEMOLITION AND RELOCATION WORKS APPLICABLE TO THE EXISTING AGED CARE FACILITY.
 - THE FITOUT OF THE LAUNDRY SHALL BE UNDERTAKEN DURING STAGE 1.
- ### LIGHTING LAYOUT REFERENCE NOTES
- EXISTING LIGHTING IN KITCHEN TO REMAIN AND CONNECTED TO RCD PROTECTED LIGHTING SUBCIRCUITS IN DB3. REFER DRAWINGS FOR RE-LOCATE, LIGHT DAMAGED LIGHTING DRIPSPRAYER, RE-LAMP AND CLEAN ALL LUMINAIRES. REFER TO GENERAL NOTES ON DRAWING E101.
 - SPOT LIGHTS TO BE SURFACE BRACKET MOUNTED ON VERTICAL WALL. FINAL LOCATION TO BE DETERMINED ON SITE WITH THE ARCHITECT. EACH SPOT LIGHT SHALL BE SEPARATELY SWITCHED FROM LIGHT SWITCHING PANEL. LSP.
 - 2-0FF FL. FLUORESCENT LUMINAIRES MUST ALIAD VERTICALLY IN SIOE OF CUPBOARD BEHIND PELTICE BY ARCHITECT. TO BE SWITCHED FROM LIGHT SWITCHING PANEL. LSP.
 - F3 FLUORESCENT LUMINAIRES UNDER BENCH INSTALLED 50mm FROM BENCH EDGE TO THROW LIGHT TO THE BACK OF THE BENCH.
 - NEW LIGHTING IN THE LAUNDRY SHALL BE SUPPLIED FROM NEW DISTRIBUTION BOARD DB3. DISCONNECT AND REMOVE ALL REDUNDANT LIGHTING FIXTURES FROM DB3. FINAL LOCATION OF THE LUMINAIRES SHALL BE DETERMINED ON SITE TO SUIT THE FINAL LAYOUT OF THE LAUNDRY EQUIPMENT.
 - RECESS F2 LUMINAIRE SINKING FROM WALL.
 - EXISTING LIGHT SWITCHING ARRANGEMENT TO REMAIN.
 - EXISTING LIGHT AND POWER IN THE FREEZER ROOM TO REMAIN.
 - EMV'S DEBATES EMT TYPE EMERGENCY LUMINAIRE BUT SUITABLE FOR SURFACE MOUNTING.
 - FINAL LOCATION OF PA SPEAKERS IN THE CHAPEL TO BE COORDINATED WITH THE AUDIO VISUAL CONSULTANT AND THE ARCHITECT.
 - HEIGHT OF P1 LUMINAIRE ABOVE FLOOR LEVEL TO UNDERSCORE OF LUMINAIRE TO BE 3000mm. REFER TO ARCHITECTS LATEST REVISED ROOM DATA SHEETS 611 AND 611A.
 - EXISTING LIGHTING INSTALLATION INCLUDING EMERGENCY LIGHTING EXIT SIGNS AND SMOKE ALARMS TO REMAIN. ADJUST EXISTING LIGHTING CIRCUITS AS NECESSARY AND CONNECT TO NEW BRIDGING NEW WIRING PROVIDE NEW LIGHT SWITCHES AS INDICATED.
 - ALLOW FOR THE DISCONNECTION AND REMOVAL OF THE EXISTING RECESSED DOWNLIGHTS FROM THE CEILING AND MAKE GOOD.
 - ADJUST LIGHTING LAYOUT TO SUIT NEW WALL LOCATIONS.
 - CONTRACTOR SHALL CONFIRM THE FINAL LOCATION OF THE FIXTURES IN THE CEILING SPACE OF THE ADMINISTRATION AREA PRIOR TO UNDERTAKING THE CUTOUTS IN THE CEILING FOR LINEAR LUMINAIRE TYPE A1 AND A2. ADJUST THE LOCATION OF RECESSED DOWNLIGHTS, EMERGENCY LIGHTING AND PA SPEAKERS TO AVOID THE FIXTURES IN THE CEILING SPACE.

