

# RCD PERIODIC INSPECTION LIST

## Monthly Test of Residual Current Devices (RCD's)

Company Name:

**X STAFF ELECTRICAL**

Site/Project Name or Location:


**ASSIST CENTRE DB-4**

Tested tripping time of RCD's (using RCD Tester)  
(FAST TRIP FOR TYPE 1, 2 OR 3 MUST BE LESS THAN 40 MS)

RCD Type and Location	Nominal Trip Current mA	Test Results to include both reverse phase relationship readings in <u>Milliseconds (mS)</u>								Action Taken for Unsatisfactory Results
		X1/2 No Trip Time		X1 Trip Time		X5 Fast Trip Time				
		0°	180°	0°	180°	0°	180°			
TYPE-1 DB-4	30mA	ms	ms	ms	ms	ms	ms	ms		
CB-Nº										
1	"	OL	OL	20	31	18	10			
3	"	OL	OL	19	30	18	9			
5	"	OL	OL	20	31	18	9			
7	"	OL	OL	20	30	18	9			
9	"	OL	OL	20	30	18	8			
11	"	OL	OL	19	30	18	9			
13	"	OL	OL	19	30	18	9			
15	"	OL	OL	17	24	18	9			
17	"	OL	OL	20	24	18	8			
19	"	OL	OL	19	24	14	8			
21	"	OL	OL	19	24	18	9			
23	"	OL	OL	20	28	18	8			
25	"	OL	OL	19	24	18	8			
27	"	OL	OL	18	28	18	8			
29	"	OL	OL	19	24	18	9			
31	"	OL	OL	18	28	18	8			
33	"	OL	OL	18	28	18	8			
35	"	OL	OL	18	28	18	8			
37	"	OL	OL	18	28	18	8			
39	"	OL	OL	17	24	13	8			
41	"	OL	OL	18	28	18	8			

Name of Licence Holder Conducting Tests: **Tom Grose**

Wiring Licence No: **A-25308**

Signature: 

Date: **6/6/2014**

## Monthly Test of Residual Current Devices (RCD's)

Company Name: .....

Site/Project Name or Location: .....

Tested tripping time of RCD's (using RCD Tester)  
(FAST TRIP FOR TYPE 1, 2 OR 3 MUST BE LESS THAN 40 MS)

[illegible]

Name of Licence Holder Conducting  
Wiring Licence No: **A-25308**

A-25308

Signature:

Test: Tony Groves  
Date: 6/16/14  
Signature: [Signature]