



ELECTRONIC SYSTEMS FOR INTEGRATED SOLUTIONS

Comtel Technologies Pty Ltd
1/1 Culverlands Street
Heidelberg West VIC 3081
T: (03) 9457 4488 F: (03) 9457 4455
E: sales@comteltechnologies.com.au
www.comteltechnologies.com.au

17 June, 2014

Re: High level FIP interface to Nurse Call

In reference to the FIP interfacing to the nurse call:

A high level interface from the main FIP to the nurse call has been connected and tested. Data was received at the nurse call head end and the data from the FIP is being passed directly onto the Spectralink handsets.

Regards,

Darren Shield

COMTEL TECHNOLOGIES PTY LTD